



Title: Sound Absorption Test Results

Product: 1/2" Poly Max Baffle - 12" Depth spaced 12" on-center

Application: Ceiling Baffle


Testing Standard: ASTM C423-17 (Type J Mount)

Test Date: 4/15/2021

Why this test: This test evaluates a products efficiency of absorbing sound at multiple frequencies. The test simulates the product’s acoustical performance when suspended in a baffle configuration. Results are presented in Sabins per Unit, a unit of absorption commonly used for spaced suspended panels. The Average Sabins per Unit is average Sabin per Unit at NRC frequencies (250 Hz, 500 Hz, 1000 Hz, 2000 Hz).

Test Result Summary: Average Sabins per Unit - 2.85

Avg. Sabins per Unit	
2.85	
Frequency (Hz)	Sabins / Unit
100	0.67
125	1.29
160	0.79
200	0.69
250	1.47
315	1.71
400	1.93
500	2.12
630	2.45
800	2.59
1000	3.24
1250	3.49
1600	4.20
2000	4.65
2500	5.12
3150	5.40
4000	5.62
5000	5.18



Test ID: ESP035429P-23

ASI TEST RESULT DISCLAIMER

ASI makes every effort to ensure the accuracy and reliability of the information provided. Laboratory testing is conducted by independent testing organizations. ASI does not guarantee that field tests or independent tests will not vary.

©2021 ASI



Element Materials Technology
662 Cromwell Avenue
St Paul, MN
55114-1720 USA

P 651 645 3601
F 651 659 7348
T 888 786 7555
info.stpaul@element.com
element.com

SOUND ABSORPTION TESTING CONDUCTED ON 1/2" POLYESTER ACOUSTIC BAFFLE

ASI
123 Columbia Court, N.
Chaska, MN 55318

Date: April 27, 2021
Author: Mark Coopet
Report Number: ESP035429P-23 R1

Customer PO: 00081905



EAR Controlled Data: This document contains technical data whose export and re-export/retransfer is subject to control by the U.S. Department of Commerce under the Export Administration Act and the Export Administration Regulations. The Department of Commerce's prior written approval is required for the export or re-export/retransfer of such technical data to any foreign person, foreign entity or foreign organization whether in the United States or abroad.

These commodities, Technology, or software were exported from the United States in accordance with the Export Administration Regulations. Diversion contrary to U.S. law is prohibited.

This project shall be governed exclusively by the General Terms and Conditions of Sale and Performance of Testing Services by Element Materials Technology. In no event shall Element Materials Technology be liable for any consequential, special or indirect loss or any damages above the cost of the work.

Ear Controlled Data

This Page Alone is not a complete report

Noise Reduction Coefficient (ASTM C423-17)

INTRODUCTION:

This report presents the results of acoustical testing of 1/2" Polyester Acoustic Baffles. This testing was requested by Mr. Joe Satek and was completed on April 15, 2021.

This report must not be reproduced except in full without the approval of Element Materials Technology. The test results contained in this report pertain only to the specific assemblies tested and not necessarily to all similar constructions.

The results stated in this report represent only the specific construction and acoustical conditions present at the time of the test. Measurements performed in accordance with this standard on nominally identical constructions and acoustical conditions may produce different results.

TEST RESULTS SUMMARY:

<i>Noise Reduction Coefficient (NRC) Test</i>				Test Results		
Test #	Sample Identification	Weight (lbs)	Weight (psf)	NRC	SAA	--
23	J Mount – 1/2" Polyester Acoustic Baffle	19.5	0.27	0.35	0.34	--

Tabular and graphical presentations of the data are presented under "TEST RESULTS" below.

SPECIMEN DESCRIPTION: (Also see "Test Results")

Each of the Acoustic Baffles were labeled for testing. Each of the 13 Baffles tested, measured 1/2" thick by 12" x 48" and weighed 1.5 lbs. each. Each of the baffles were spaced 12" on-center. The distance from the bottom of the baffles to the test floor measured 32 1/2".

Test Specimen:	
Dimension:	13 Pieces each 48 in. x 12 in.
Total Weight:	19.5 lbs.
Overall Surface Area:	108.5 ft ² (10.13 M ²)

Environmental Conditions:	
Temperature (°C):	21.6
Humidity (%):	48
ATM (hPa)	985

Individual Baffle:	
Dimension:	48 in. x 12 in.
Average Weight:	1.5 lbs.
Surface Area:	8.38 ft ² (.779 M ²)
Material Thickness:	1/2 in.

Reverberant Room Volume
5825 ft ³ (83m ³)

TEST PROCEDURE AND EQUIPMENT:

Sound Absorption Test

ASTM C 423-17, “Sound Absorption and Sound Absorption Coefficient by the Reverberation Room Method”, was followed in every respect. The panels were tested in a Type J Mounting in accordance to ASTM E795-16.

NRC was calculated by rounding the sound absorption coefficients for 250, 500, 1000 and 2000 Hz to the nearest 0.05. SAA was calculated by rounding the sound absorption coefficients for the twelve frequencies from 200 Hz to 2500 Hz to the nearest 0.01.

The Noise Reduction Coefficient (NRC) is a scalar representation of the amount of sound energy absorbed upon striking a particular surface. An NRC of 0 indicates perfect reflection; an NRC of 1 indicates perfect absorption.

The Sound Absorption Average (SAA) is the average of the absorption coefficients for the twelve one-third octave bands from 200 to 2500 Hz.

The higher the SAA or NRC value, the better the material absorbs sound.

TEST EQUIPMENT:

Item Description	ID #	Manufacturer/Model	Serial #	Calibration Due
1/2" Pressure Condenser Microphone	PT-162-075	GRAS/40AD	19220-1244	7/17/2021
Microphone Calibrator	MM-440-003	Bruel & Kjaer/4230	282266	7/17/2021
Data Acquisition Module	PT-162-107	National Instruments/NI9234	1735986-1893EB3	6/8/2021
Temp and Humidity Transmitter	PT-162-077	Dwyer Instruments/Series RH	M90714-E4SV-Y	6/4/2021


TEST DATA:

Note: There is currently no standardized method for calculating the Absorption Coefficients of sound absorptive objects that are separated or spaced. The performance of sound absorptive objects separated or spaced should not be directly compared to specimen tested as a single unit in a rectangular area (e.g. mounting types A or E as defined by ASTM E795-16)

Sabins/Unit Data

Frequency (Hz)	Total Absorption (M ²)	Total Absorption (Sabins)	Absorption (Sabins/Unit)
100	0.81	8.72	0.67
125	1.56	16.79	1.29
160	0.96	10.33	0.79
200	0.83	8.93	0.69
250	1.78	19.16	1.47
315	2.06	22.17	1.71
400	2.33	25.08	1.93
500	2.56	27.56	2.12
630	2.96	31.86	2.45
800	3.13	33.69	2.59
1000	3.91	42.09	3.24
1250	4.21	45.32	3.49
1600	5.07	54.57	4.20
2000	5.62	60.50	4.65
2500	6.18	66.52	5.12
3150	6.52	70.18	5.40
4000	6.79	73.09	5.62
5000	6.26	67.38	5.18

1/2" Polyester Acoustic Baffle



SOUND ABSORPTION
ASTM C423

General Information


Project No:	ESP035429P-23
Customer:	ASI
Test Date:	04-15-2021
Specimen ID:	Half Inch Polyester Acoustic Baffle
Specimen Description:	J-Mount 1/2" - 12" - 48"
Specimen Dimensions - Area:	124.00" W x 126.00" H - 108.50 ft ²
Operator:	MJC

Data Table

	absorption empty (m ²)	absorption * sample (m ²)	Absorption Coefficient
80	4.16	0.35	0.04
100	5.70	0.81	0.08
125	3.13	1.56	0.15
160	3.23	0.96	0.10
200	4.12	0.83	0.08
250	4.00	1.78	0.18
315	3.86	2.06	0.20
400	4.03	2.33	0.23
500	4.54	2.56	0.25
630	4.77	2.96	0.29
800	5.07	3.13	0.31
1000	5.26	3.91	0.39
1250	5.80	4.21	0.42
1600	6.53	5.07	0.50
2000	7.40	5.62	0.56
2500	8.26	6.18	0.61
3150	9.31	6.52	0.65
4000	11.44	6.79	0.67
5000	13.76	6.26	0.62

Room Conditions


Temperature	21.6 °C
R.H.	48 %
ATM	985 hPa



NRC
0.35

SAA
0.34

* based on an extended plane area of 108.50 ft²



Mark Coopet
Technician, Product Validation
Building Materials and Acoustics
651-645-3601

Ear Controlled Data



1/2" Polyester Acoustic Baffle (12" O.C.)